



TERRA-THERM INC.

Box 428, 13128 240th Ave., New Richland, MN 56072

Phone 507-463-3213 Fax 507-463-3215

Website: www.TTherm.com

•Geothermal Systems

•Radiant Floor Heating

•Air Handling Systems

TERRA-THERM, INC. FAN COILS

Prices Effective September 15, 2009 (Supercedes July 1, 2008)

PART NO.	MODEL #	CFM	GPM	HTG.	CLG.	PUMP SELECTION	Braeburn		
				BTU'S	BTU'S		Thermostat	Air Filter	
M1-6001	24CWA - 8KW	600	3.0	20,700	17,600	UP15-42	3200	16" X 20"	
M1-6001	24CWA - 8KW	800	3.5	25,900	21,500	UP15-42	3200	16" X 20"	
M1-6001	24CWA - 8KW	800	6.5	29,100	27,600	UP15-42	3200	16" X 20"	
M1-6004	36CWA - 10KW	1000	4.0	31,100	27,400	UP15-42 or UP26-99	3200	16" X 20"	
M1-6004	36CWA - 10KW	1200	5.0	37,000	32,100	UP15-42 or UP26-99	3200	16" X 20"	
M1-6004	36CWA - 10KW	1200	8.0	40,900	38,500	UP15-42 or UP26-99	3200	16" X 20"	
M1-6006	48CWA - 10KW	1400	6.0	44,400	37,500	UP26-99	3200	20" X 25"	
M1-6006	48CWA - 10KW	1600	6.0	48,000	39,700	UP26-99	3200	20" X 25"	
M1-6006	48CWA - 10KW	1600	10.0	54,300	49,200	UP26-99	3200	20" X 25"	
M1-6010	60CWA - 15KW	1600	6.5	51,300	45,500	UP26-99	3200	20" X 25"	
M1-6010	60CWA - 15KW	2000	7.0	59,800	50,900	UP26-99	3200	20" X 25"	
M1-6010	60CWA - 15KW	2000	13.0	69,200	65,400	UP26-99	3200	20" X 25"	
FILTERS FOR ABOVE FAN COILS									
D25-1620	16" X 20" X 1" Max-Aire Gold Filter (24CWA & 36CWA Fan Coil)								
D25-2025	20" X 25" X 1" Max-Aire Gold Filter (48CWA & 60CWA Fan Coil)								

All units come with electric heat and we stock all units.

Heating BTU based on 115°F average hot water and 70°F return air.

Cooling BTU based on 45°F average chilled water and 75°F return air.

FREIGHT: FOB New Richland, MN

Physical Dimensions

Model No.	A	B	C	D	E	F	G
24 - 36CWA	17 1/2	21	15	17 1/2	16	12 5/8	39 3/4
48 - 60 CWA	21 1/2	25	19 1/4	22 1/4	19 5/8	17 1/4	49 3/4

